

WELL COMPLETION REPORT

3/71

PUTNAM COUNTY DEPARTMENT OF HEALTH

Division of Environmental Health Services
COUNTY OFFICE BUILDING - CARMEL, NEW YORK

This report is to be completed by well driller and submitted to County Health Department together with laboratory report of analysis of water sample indicating water is of satisfactory bacterial quality before certificate of construction compliance is issued.

REPORT MUST BE SUBMITTED WITHIN 30 DAYS OF WELL COMPLETION

P1108

OWNER	NAME Kenneth Nelson		ADDRESS Old Road		Brewster, NY	
LOCATION OF WELL	(No. & Street) SAME		(Town)		(Lot Number)	
PROPOSED USE OF WELL	<input checked="" type="checkbox"/> DOMESTIC <input type="checkbox"/> PUBLIC SUPPLY		<input type="checkbox"/> BUSINESS ESTABLISHMENT <input type="checkbox"/> INDUSTRIAL		<input type="checkbox"/> FARM <input type="checkbox"/> AIR CONDITIONING <input type="checkbox"/> TEST WELL <input type="checkbox"/> OTHER (Specify)	
DRILLING EQUIPMENT	<input checked="" type="checkbox"/> ROTARY <input type="checkbox"/> CABLE PERCUSSION		<input checked="" type="checkbox"/> COMPRESSED AIR PERCUSSION <input type="checkbox"/> OTHER (Specify)			
CASING DETAILS	LENGTH (feet) 30	DIAMETER (inches) 6	WEIGHT PER FOOT 19 lbs.	<input checked="" type="checkbox"/> THREADED <input type="checkbox"/> WELDED	DRIVE SHOE <input checked="" type="checkbox"/> YES <input type="checkbox"/> NO	WAS CASING GROUTED? <input checked="" type="checkbox"/> YES <input type="checkbox"/> NO
YIELD TEST	<input type="checkbox"/> BAILED <input checked="" type="checkbox"/> PUMPED <input type="checkbox"/> COMPRESSED AIR		HOURS 6	G.P.M. 20	YIELD (G.P.M.) 20	
WATER LEVEL	MEASURE FROM LAND SURFACE—STATIC (Specify feet) 30'		DURING YIELD TEST (feet)		Depth of Completed Well in feet below Land surface:	
SCREEN DETAILS	MAKE					LENGTH OPEN TO AQUIFER (feet)
	SLOT SIZE	DIAMETER (inches)	IF GRAVEL PACKED:	Diameter of well including gravel pack (inches):	GRAVEL SIZE (inches)	FROM (feet) TO (feet)
DEPTH FROM LAND SURFACE	FORMATION DESCRIPTION		Sketch exact location of well with distances, to at least two permanent landmarks.			
FEET to FEET						
0	8	Drilling in overburden clay and boulders				
		Hit rock at 8 feet				
8	30	Drilling in rock, set casing grouted.				
30	130	Drilling in rock granite.				
If yield was tested at different depths during drilling, list below						
FEET		GALLONS PER MINUTE				

RECEIVED

PUTNAM CO. DEPT. OF HEALTH

Handwritten signature: H. T. Bergh